

## Fire Apparatus Access

From: Clint Benson (clint.benson@ontariooregon.org)

To: hatjhorses@yahoo.com

Date: Friday, January 5, 2024 at 04:37 PM MST

Good afternoon, Ms. Arreola:

For the Ontario Rural Fire Protection District to confirm fire apparatus access to a property/structure, we need to confirm that access meets the Oregon Fire Code. Following is a summary of the code requirements for access:

- Access roads (driveways) must extend to within 150' of all portions of the residence.
- An unobstructed width of not less than 20' and a vertical clearance of 13-6" must be met.
- An all-weather surface capable of supporting the loads of fire apparatus (typically 80,000 pounds).
- A maximum grade of 10%
- Dead ends greater than 150' in length require a fire apparatus turnaround: 96' diameter cul-de-sac, 60' "Y", or a 120' hammerhead.

I hope this helps. Please let me know if you have any questions.

Clint Benson  
Fire Chief  
Ontario Fire and Rescue  
Ontario Rural Fire Protection District  
541-709-0320 Cell  
541-881-3233 Office



EXHIBIT # 2