



# **NYSSA VOLUNTEER FIRE DEPARTMENT**

**203 Good Ave Nyssa, Oregon 97913  
Station (541) 372-3800 Fax (541)372-5740  
Dispatch (541) 372-3825**



**Fire Chief  
Eric Menchaca**

**Assistant Chief  
Marvin Seuell**

To whom it may concern,

**RE: 1288 Cow Hollow Rd. Nyssa, OR 97913**

This is in regard to Township: 20, Range: 45, Section: 12, Tax lot: 1200, on 1288 Cow Hollow Rd. Nyssa, OR 97913. This address is inside the Nyssa Rural Fire Protection District. Therefore, we provide fire coverage to that address and have no objection with the partition. The Nyssa Rural Fire Protection District is OK with Homeland Fireworks Inc. to move 7 40' Connex containers for fireworks storage so long as storage units are in accordance with ATF, NFPA, Oregon OAR Chapter 837 rules and regulations, the driveway to the site is a 20-foot-wide all-weather road with adequate all-weather turnaround space at the end supporting at least 60,000 lbs. An unobstructed height of 14 feet and grade should not exceed 10%. Any questions or concerns feel free to contact me. Thank you for your time.

Sincerely,  
Chief Eric Menchaca  
Nyssa Fire Department  
Ph- 541-372-3800  
Fax- 541-372-5740  
Cell- 541-735-7080

**EXHIBIT #** 3