

Eric Evans

From: Adele Schaffeld <adele.schaffeld@bldgmalheurco.org>
Sent: Tuesday, March 8, 2022 9:51 AM
To: Tatiana Burgess; Alexis McDaniel
Cc: Eric Evans
Subject: FW: Aircraft Hangar Project
Attachments: Aircraft Hangar Fire Suppression Flowchart.pdf

These comments are for the hanger on the planning agenda. They initially contacted the state for comments. The attachment goes with the comments.

File #2022-02-006

Thank you

Adele

From: MCMULLEN Eric T * DCBS <Eric.T.MCMULLEN@dcbs.oregon.gov>
Sent: Wednesday, January 12, 2022 12:36 PM
To: Adele Schaffeld <adele.schaffeld@bldgmalheurco.org>
Cc: ROCCO Anthony J * DCBS <Anthony.J.ROCCO@dcbs.oregon.gov>; WILLIAMS Jeremy G * DCBS <Jeremy.G.WILLIAMS@dcbs.oregon.gov>; RAMOS Francisco M * DCBS <Francisco.M.RAMOS@dcbs.oregon.gov>
Subject: Aircraft Hangar Project

Hi Adele,

I received a call yesterday from a contractor who is working on a proposal for an aircraft hanger in your jurisdiction, he called us because he thought the state served the area. He was mostly asking about fire suppression requirements. I walked him through the requirements as best I could with limited project information and directed him to you to verify the appropriate hangar group so that he can apply the correct fire suppression requirements. It sounds like the hangar will be at a private ranch and around 10,000sqft.

I've attached a flow chart that I created that may be helpful as OSSC Section 412 can be cumbersome, to say the least.

I've copied our program team on this correspondence for consistent communication purposes.

Regards,
Eric



Oregon
Building
Codes
Division

Eric T. McMullen
Senior Building Code Specialist
503.930.8849 | www.oregon.gov/bcd
eric.t.mcmullen@bcds.oregon.gov

"Working with Oregonians to ensure safe building construction while supporting a positive business climate."

EXHIBIT # 4

**Aircraft Hangar Fire Suppression
by Hangar Group
(OSSC 412.3.6 & Table 412.3.6)**

