

## Tatiana Burgess

---

**From:** Terry Leighton <terry.leighton@ontariooregon.org>  
**Sent:** Wednesday, May 4, 2022 4:13 PM  
**To:** Tatiana Burgess  
**Subject:** RE: Planning letter 473 Jacobson Gulch

My only requirements would be to have the address well marked at the road with minimum of 4" numbers and have a minimum of 5 pound ABC fire extinguisher. Thanks for asking. Terry



**Terry Leighton | Fire Chief**  
444 SW 4th. St. Ontario, OR 97914  
Office: 541-881-3233  
Cell: 208-941-9158  
[Terry.Leighton@ontariooregon.org](mailto:Terry.Leighton@ontariooregon.org)

---

**From:** Tatiana Burgess <Tatiana.Burgess@malheurco.org>  
**Sent:** Wednesday, May 4, 2022 1:37 PM  
**To:** Terry Leighton <terry.leighton@ontariooregon.org>  
**Subject:** RE: Planning letter 473 Jacobson Gulch

Good afternoon Terry!

I have another question regarding this property. So the original plan was that they were only going to have an outdoor wedding venue. Now, besides that, the wife will run a hair salon out of the first floor of the house. They will have a dedicated door just for the salon... My question – do they need any special permission from you? We haven't had such a request yet, when they are converting existing living space into a business... It sounds like she is estimating a small number of clients.

Please tell me what are your thoughts.

Thank you so much!

Tatiana

---