



PUBLIC HEALTH DIVISION
Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

750 SE Emigrant Ave., Suite 150
Pendleton, OR 97801
(541) 276-8006
FAX (541) 276-4778
www.healthoregon.org/dwp

July 19, 2022

Eric Evans
Malheur County Planning Department
251 "B" Street West #12
Vale, Oregon 97918

Re: Comments on Proposed Mennonite School's Water System

Based on information provided in the Conditional Use Application, it appears the proposed school will meet the definition of a non-transient non-community public water system and be subject to regulation by the Oregon Health Authority – Drinking Water Services. Plans for the water system must be submitted for review prior to construction per OAR 333-061-0060 to ensure the facilities will meet current construction standards.

If you have any questions or concerns, please contact me at (541) 966-0900 or by email at william.h.goss@dhsaha.state.or.us

Sincerely,

William Goss, P.E.
Regional Engineer

c: OHA-DWS, Portland