



Ontario Rural Fire Protection

District #7-302

444 SW 4th Street

Ontario, OR 97914

Voice (541) 881-3230

Fax (541) 889-7121

clint.benson@ontariooregon.org

February 23, 2023

Larry D. Hinton, PE
CK3, LLC
368 SW 5th Avenue
Ontario, OR 97914
larry@ck3llc.net

**RE: Partners Produce Evaporation Pond
Malheur County Conditional Use Permit**

Mr. Hinton,

I have reviewed the referenced conditional use permit application. My comments are as follows:

1. The project shall include a minimum 20' wide fire department access road. The access road shall include a way for fire apparatus to turn around by including a looping road system, 120' hammerhead, 60' "Y", or 96' diameter cul-de-sac in accordance with the Oregon Fire Code.

Please let me know if you have any questions.

A handwritten signature in blue ink, appearing to be "CB", written over a horizontal line.

Clint Benson
Fire Chief