

Rural Road Assessment District No.3

230 North Oregon – P.O. Drawer 99

Ontario . OR 97914

In Response to a request for property access to tax lot 801 on the west side of Lincoln dr. The Rural Road Assessment #3 Requests that a 15" culvert drainage pipe be installed at access point to allow run off/ irrigation water to pass, With that stipulation met the District sees no other issues to be addressed.

Rural Road Dist. #3

Karl Shrum

Supervisor

EXHIBIT # 3