

Rural Road Assessment District No.3

230 North Oregon – P.O. Drawer 99

Shop Address 4400 baker rd

Ontario . OR 97914

In regards to a conditional use permit application for the location 275 Evergreen Rd the Rural Road Assessment #3 requires a minimum but not limited to 10 inch Dual wall Hancor style culvert for the access point to the property from Evergreen Rd. RRA#3 does not foresee any negative traffic or maintenance impact to the district.

Karl Shrum

supervisor

EXHIBIT # 4