

Rural Road Assessment District No.3

230 North Oregon – PO. Drawer 99

Ontario, OR 97914

In Response to Daniel Mink's CUP application the Rural Road Assessment #3 Requests that a 10" dual wall ABS drainage pipe 40 ft long be installed at access point to allow run off water to pass. The Rural Road Assessment #3 has no other request or objections to the application since it will not interfere with any maintenance or improvements done by the district.

Rural Road Dist. #3

Karl Shrum

Supervisor