

Drydale

Rural Fire District Letter

I hereby certify that the property proposed for Border Region Housing (BRH) rezoning, which is a portion of Tax Lot 1600, Map 19546E23 and shown on the attached map (include map showing precise location of homesites, lots and/or parcels under review by the Border Region Review Board) within and entitled to fire prevention and suppression services by

Nyssa
Rural Fire District Name

The attached letter describes fire prevention standards required that must be met prior to final plat approval or home construction, as appropriate.

Signed this 19 day of March, 2026

Signature: Martin Senell

Name: Martin Senell

Title: Chief

EXHIBIT # 2



Nyssa Fire Department

203 Good Ave.
Nyssa, OR 97913

Phone: 541-372-3800
Fax: 541-372-5740

To whom it may concern,

RE: Nyssa, OR 97913

This is in regard to Tax lot 1600 , Map 19S46E23, Lot size 2 Ac. This address is near Grey blvd and Columbia Ave. This address is inside the Nyssa Rural Fire Protection District..Therefore, we provide fire coverage to that address and have no objection with the partition. We are OK with a a new home being built on this property so long as the driveway to the home site is a 20 foot wide all weather road with adequate turnaround space at the end. If property is sold before a new home is built, new owner will have to obtain a new letter for approval.. Any questions or concerns feel free to contact me. Thank you for your time.

Sincerely,

Chief Marvin Souell
Marvin Souell
Nyssa Fire Department

Ph- 541-372-3800

Fax- 541-372-5740

Cell- 541-235-3204

→ Grey Blvd →

— Columbia Ave —

Drydole

